

October 22, 2001

Ms. Grisell V. Diaz-Cotto  
Emergency and Remedial Response Division  
United States Environmental Protection Agency  
Region III  
290 Broadway, 19th Floor  
New York, NY 10007-1866

Re: September 2001 Discharge Monitoring Report  
Leachate Treatment Plant, Operable Unit 1  
Kin-Buc Landfill Superfund Site

Dear Ms. Diaz-Cotto:

The September 2001 Discharge Monitoring Report (DMR) for the Leachate Treatment Plant of Operable Unit 1, Kin-Buc Landfill Superfund Site, prepared by U.S. Filter Operating Services is attached. We will provide copies of the DMR to Ian Curtis and Susan Dietrick at the NJDEP.

Should you have any questions concerning the DMR or other site items, please contact me or Glenn Grieb at the Kin-Buc site.

Very truly yours,  
USFilter Operating Services  
On behalf of SCA Services, Inc.,



Dennis J. Duryea, P.E.  
Area Manager

Enclosure

cc: Ian Curtis - NJDEP  
Susan Dietrick - NJDEP  
Stephen Joyce - SCA  
Carl Januszkiewicz - Waste Management  
Glenn Grieb - USFOS, Kin-Buc  
File



NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DIVISION OF WATER QUALITY

MONITORING REPORT - TRANSMITTAL SHEET

NJPDES NO.

*					
---	--	--	--	--	--

\*NJ Permit Equivalent

REPORTING PERIOD

M	o.	Y	r.
1	0	0	1

M	o.	Y	r.
1	0	0	1

PERMITTEE: Name: SCA Services, Inc.  
Address: 383 Meadow Road  
Edison, New Jersey 08817

FACILITY: Name: Kin-Buc Landfill  
Address: 383 Meadow Road  
Edison, New Jersey 08817  
Telephone: 732-572-4743

FORMS ATTACHED (Indicate Quantity of Each)

Operating Exceptions

SLUDGE REPORT-SANITARY

   T-VWX-007    T-VWX-008    T-VWX-009  
   EPA Form 3320-1

DYE TESTING YES    NO X

SLUDGE REPORT-INDUSTRIAL

   T-VWX-010A    T-VWX-010B

TEMPORARY BYPASSING    X

WASTEWATER REPORTS

   T-VWX-011    T-VWX-012    T-VWX-013

DISINFECTION INTERRUPTION    X

GROUNDWATER REPORTS

   T-VWX-015(A,B)    T-VWX-016    T-VWX-017  
   ELECTRONIC SUBMISSION

MONITORING MALFUNCTIONS    X

UNITS OF OPERATION    X

OTHER    X

NPDES DISCHARGE MONITORING

   EPA Form 3320-1


(Detail any "Yes" on reverse side in appropriate space.)


NOTE: The "Hours Attended at Plant" on the reverse of this sheet must also be completed.

AUTHENTICATION I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

LICENSED OPERATOR

PRINCIPAL EXECUTIVE OFFICER OR  
DULY AUTHORIZED REPRESENTATIVE

Name (Printed) Dennis J. Duryea  
Grade & Registry No. (N-4) 0014528  
Signature 

Name (Printed) Dennis J. Duryea  
Title (Printed) Plant Operations Manager  
Signature 



PERMITTEE NAME/ADDRESS

NAME SCA SERVICES, INC.  
ADDRESS 383 MEADOW ROAD  
EDISON, NEW JERSEY 08817


FACILITY LOCATION

KIN-BUC LANDFILL  
EDISON, NEW JERSEY  
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT	001
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD			MONITORING PERIOD		
YEAR	MO	DAY	YEAR	MO	DAY
01	09	01	01	09	30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.018938	0.037186	MGD	*****	*****	*****	***		continuous	flow meter
	PERMIT REQUIREMENT	REPORT	ONLY		*****	*****	*****			continuous	flow meter
pH	SAMPLE MEASUREMENT			***	7.90		8.73	S.U.	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		6.0	*****	9.0			weekly	grab
PETROLEUM HYDROCARBONS	SAMPLE MEASUREMENT			***	*****	<0.5	<0.5	mg/l	0	2/month	grab
	PERMIT REQUIREMENT	*****	*****		*****	10	15			2/month	grab
COD	SAMPLE MEASUREMENT	19.6	20.2	kg/day	*****	191	205	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT	ONLY			2/month	comp.
BOD	SAMPLE MEASUREMENT			***		<2.00	<2.00	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****			2/month	comp.
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT	<0.0876	<0.1136	kg/day	*****	<1.0	<1.0	mg/l	0	1/week	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	30	45(1)			weekly	comp.
DISSOLVED OXYGEN	SAMPLE MEASUREMENT			***	6.8		7.8	mg/l	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		4.0 MIN. Instantaneous	*****	*****			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE
Dennis Duryea Area Manager									732 572-4743		01 / 10 / 22
TYPED OR PRINTED							AREA CODE		NUMBER		YEAR MO DAY
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS:

NAME

ADDRESS

FACILITY

LOCATION

ATTN:

SCA SERVICES, INC.  
383 MEADOW ROAD  
EDISON, NEW JERSEY 08817  
  
KIN-BUC LANDFILL  
EDISON, NEW JERSEY  
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
01	09	01	01	09	30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BENZENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.009	0.02		*****	57	134			2/month	grab	
CHLOROBENZENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab	
1,1 DICHLOROETHENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.003	0.009		*****	22	59			2/month	grab	
ETHYLBENZENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.008	0.025		*****	52	164			2/month	grab	
TOLUENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.004	0.011		*****	28	74			2/month	grab	
1,2-TRANSDICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.004	0.009		*****	25	60			2/month	grab	
NAME/TITLE: PRINCIPAL EXECUTIVE OFFICER		<small>I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 &amp; 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)</small>						TELEPHONE		DATE		
Dennis Duryea Area Manager								732 572-4743		01 10 22		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						732	572-4743	01	10	22
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)						AREA CODE	NUMBER	YEAR	MO	DAY

PERMITTEE NAME/ADDRESS

NAME  
ADDRESSSCA SERVICES, INC.  
383 MEADOW ROAD  
EDISON, NEW JERSEY 08817FACILITY  
LOCATION  
ATTN:KIN-BUC LANDFILL  
EDISON, NEW JERSEY  
CARL JANUSZKIEWICZNATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
01	09	01		01	09	30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.010		*****	26	69			2/month	grab
VINYL CHLORIDE	SAMPLE MEASUREMENT	<0.00021	<0.00028	kg/day	*****	<2.5	<2.5	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.008	0.016		*****	52.8	106			weekly	grab
ACENAPHTHYLENE	SAMPLE MEASUREMENT	<0.000081	<0.000105	kg/day	*****	<0.91	<0.93	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)ANTHRACENE	SAMPLE MEASUREMENT	<0.000077	<0.000100	kg/day	*****	<0.86	<0.88	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)PYRENE	SAMPLE MEASUREMENT	<0.000041	<0.000054	kg/day	*****	<0.47	<0.48	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(ghi)PERYLENE	SAMPLE MEASUREMENT	<0.000046	<0.000060	kg/day	*****	<0.52	<0.53	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(k)FLUORANTHENE	SAMPLE MEASUREMENT	<0.000079	<0.000103	kg/day	*****	<0.89	<0.91	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Dennis Duryea Area Manager							732 572-4743		01 10 22		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS

NAME

ADDRESS

SCA SERVICES, INC.  
383 MEADOW ROAD  
EDISON, NEW JERSEY 08817

FACILITY  
LOCATION  
ATTN:

KIN-BUC LANDFILL  
EDISON, NEW JERSEY  
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE/ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
01	09	01		01	09	30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IDENO(1,2,3cd) PYRENE	SAMPLE MEASUREMENT	<0.000051	<0.000065	kg/day	*****	<0.57	<0.58	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
PHENANTHRENE	SAMPLE MEASUREMENT	<0.000048	<0.000063	kg/day	*****	<0.55	<0.56	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	5.4(2)			weekly	grab
ALDRIN	SAMPLE MEASUREMENT	<0.000047	<0.000055	kg/day	*****	<0.048	<0.048	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.000133	0.00026		*****	0.0875	0.176			monthly	grab
4,4-DDT	SAMPLE MEASUREMENT	<0.000084	<0.0000109	kg/day	*****	<0.096	<0.096	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.0000578	0.000146		*****	0.38	0.765			weekly	grab
PCB-1242	SAMPLE MEASUREMENT	<0.0000254	<0.0000330	kg/day	*****	<0.29	<0.29	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1248	SAMPLE MEASUREMENT	<0.0000254	<0.0000330	kg/day	*****	<0.29	<0.29	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1254	SAMPLE MEASUREMENT	<0.0000254	<0.0000330	kg/day	*****	<0.29	<0.29	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)				TELEPHONE		DATE			
Dennis Duryea Area Manager						732 572-4743		01 10 22			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE		NUMBER		YEAR MO DAY	
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS

NAME  
ADDRESS

SCA SERVICES, INC.  
383 MEADOW ROAD  
EDISON, NEW JERSEY 08817

FACILITY  
LOCATION  
ATTN:

KIN-BUC LANDFILL  
EDISON, NEW JERSEY  
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT PERMIT NUMBER			DISCHARGE NUMBER 001			
MONITORING PERIOD						
YEAR 01	MO 09	DAY 01	TO	YEAR 01	MO 09	DAY 30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PCB-1260	SAMPLE MEASUREMENT	<0.0000254	<0.0000330	kg/day	*****	<0.29	<0.29	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
ARSENIC	SAMPLE MEASUREMENT	<0.00087	<0.00113	kg/day	*****	<10	<10	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.013	0.026		*****	85.8	172			weekly	comp
CADMIUM	SAMPLE MEASUREMENT	<0.00043	<0.00056	kg/day	*****	<5.0	<5.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.0073	0.017		*****	48.2	112			weekly	comp
CHROMIUM	SAMPLE MEASUREMENT	<0.00087	<0.00113	kg/day	*****	<10.0	<10.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.030	0.080		*****	198	396			weekly	comp
COPPER	SAMPLE MEASUREMENT	0.00017	0.00022	kg/day	*****	2.0	2.1	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
LEAD	SAMPLE MEASUREMENT	<0.00043	<0.00056	kg/day	*****	<5	<5	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
NICKEL	SAMPLE MEASUREMENT	<0.0035	<0.0045	kg/day	*****	<40	<40	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.140	0.281		*****	924	1850			weekly	comp
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)				TELEPHONE		DATE			
Dennis Duryea Area Manager						732 572-4743		01 10 22			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE		NUMBER		YEAR MO DAY	
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									



PERMITTEE NAME/ADDRESS

NAME  
ADDRESS


SCA SERVICES, INC.  
383 MEADOW ROAD  
EDISON, NEW JERSEY 08817

FACILITY  
LOCATION  
ATTN:

KIN-BUC LANDFILL  
EDISON, NEW JERSEY  
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT PERMIT NUMBER			DISCHARGE NUMBER 001		
MONITORING PERIOD					
YEAR 01	MO 09	DAY 01	TO	YEAR 01	MO 09 DAY 30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
ZINC	SAMPLE MEASUREMENT	<0.0017	<0.0022	kg/day	*****	<20	<20	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.177	0.356		*****	1170	2350			weekly	comp
CYANIDE	SAMPLE MEASUREMENT	0.00094	0.00142	kg/day	*****	10.6	12.5	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.002	0.004		*****	13.2	28.4			weekly	comp
ALUMINUM	SAMPLE MEASUREMENT	<0.0087	<0.0113	kg/day	*****	<100	<100	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	1.40	2.81		*****	9240	18500			weekly	comp
IRON	SAMPLE MEASUREMENT	<0.0087	<0.0113	kg/day	*****	<100	<100	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	80.6	162		*****	532000	1070000			weekly	comp
ACUTE TOXICITY, (LC50)	SAMPLE MEASUREMENT			***		*****	*****	%			
	PERMIT REQUIREMENT	*****	*****		50(3)	*****	*****			see permit	equivalent
Ammonia	SAMPLE MEASUREMENT			***	*****	0.05	0.05	mg/l	0	*****	*****
	PERMIT REQUIREMENT				*****	4.9	10.0			2/month	comp
	SAMPLE MEASUREMENT			***	*****	*****	*****			*****	*****
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****			*****	*****
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)				 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE	
Dennis Duryea Area Manager								732 572-4743		01 10 22	
TYPED OR PRINTED		AREA CODE		NUMBER		YEAR		MO		DAY	
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									